

**DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet -- 1st Quarter Report 2019**

**Spills**

Spill No.	Date/Time		Type & Volume			Location		MH/pipe		Cause/Source		Water Body		Flow Restoration			Notifications		
	Date Spill Reported to DWM	Time Spill Reported to DWM	Fish Kill	Major Spill	Estimated Quantity, gals	Address of Spill	City	Manhole / Structure #	Pipe Size	Cause	Source	Receiving Stream or Waterbody	Tributary	Restoration Date	Restoration Time	Flow Restoration Action	24 hour Notice	5 Day Letter	Additional Follow-up
1	1/1/2019	17:47	N	N	5,650	2967 HENDERSON MILL ROAD	CHAMBLEE	N/A	10	PMP FLR	BYPASS PUMP MALFUNCTIONED CAUSING SPILL FROM 10(IN) SEWER MAIN	PEACHTREE BRANCH CREEK	UNNAMED	1/1/2019	19:40	INSTALLED A NEW 4(IN) BYPASS PUMP TO STOP THE SPILL AND RESTORED NORMAL FLOW	1/1/2019	1/4/2019	CCTV, CLEANING AND REPAIR WORK ORDERS COMPLETED
2	1/2/2019	0:45	N	Y	39,600	1561 ELM RIDGE WAY	STONE MTN	192-S013	8	DB	DEBRIS BLOCKED THE 8(IN) SEWER MAIN	SNAPPINGER CREEK	UNNAMED	1/2/2019	11:45	PRESSURE WASHED 8(IN) SEWER MAIN AND CLEARED THE DEBRIS(RAGS) BLOCKAGE AT 50(FT) TO RESTORE THE NORMAL FLOW	1/2/2019	1/4/2019	CCTV, CLEANING AND REPAIR WORK ORDERS COMPLETED
3	1/10/2019 (spill date 1/3/2019)	1:00	N	Y	233,540	4557 MEADOW CREEK PATH	LITHONIA	034-S090	54	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM MANHOLE	SNAPPINGER CREEK	N/A	1/5/2019	4:00	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/10/2019	1/14/2019	CCTV, CLEANING WORK ORDERS COMPLETED BY THE CONTRACTORS
4	1/4/2019	7:37	N	Y	34,500	3449 BROOKFIELD LANE	DECATUR	N/A	6	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM CLEANOUT	COBBS CREEK	UNNAMED	1/4/2019	19:10	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/4/2019	1/9/2019	CCTV, CLEANING WORK ORDERS COMPLETED
5	1/4/2019	7:40	N	Y	35,900	3433 BROOKFIELD LANE	DECATUR	187-S067	15	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM MANHOLE	COBBS CREEK	UNNAMED	1/4/2019	13:39	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/4/2019	1/9/2019	CCTV, CLEANING WORK ORDERS COMPLETED
6	1/4/2019	11:28	N	Y	48,845	4347 FLAT SHOALS PAKWAY	DECATUR	070-S050, S049, S016	30	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM MANHOLE	SHOAL CREEK	N/A	1/4/2019	14:45	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/4/2019	1/9/2019	CCTV, CLEANING WORK ORDERS COMPLETED
7	1/4/2019	8:30	N	Y	75,625	1410 COBB BRANCH DRIVE	DECATUR	197-S109	10	I&I	FOUND MANHOLE #15-197-S109 SPILLING INTO COBBS CREEK DUE TO I&I FROM HEAVY RAIN EVENT.	COBBS CREEK	UNNAMED	1/4/2019	13:05	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/4/2019	1/9/2019	CCTV, CLEANING WORK ORDERS COMPLETED
8	1/4/2019	8:50	N	Y	16,600	308 2ND AVENUE	DECATUR	213-S200	8	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM MANHOLE	SUGAR CREEK	A	1/4/2019	14:23	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/4/2019	1/9/2019	CCTV, CLEANING WORK ORDERS COMPLETED
9	1/4/2019	9:21	N	Y	20,350	3510 MISTY VALLEY ROAD	DECATUR	N/A	6	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM CLEANOUT	COBBS CREEK	UNNAMED	1/4/2019	16:08	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/4/2019	1/9/2019	CCTV, CLEANING WORK ORDERS COMPLETED
10	1/4/2019	9:24	N	Y	45,900	2060 KEHELEY DRIVE	DECATUR	N/A	4	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM CLEANOUT	DOOLITTLE CREEK	UNNAMED	1/4/2019	14:30	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/4/2019	1/9/2019	CCTV, CLEANING WORK ORDERS COMPLETED
11	1/4/2019	9:45	N	N	1,609	1615 MELANIE COURT	DECATUR	184-S004	24	I&I	FOUND EVIDENCE THAT MANHOLE SPILLED DUE TO I&I FROM STORM EVENT	SHOAL CREEK	UNNAMED	1/4/2019	10:30	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/4/2019	1/9/2019	CCTV AND CLEANING WORK ORDERS COMPLETED BY THE CONTRACTORS
12	1/4/2019	9:55	N	Y	70,000	2480 MIRIAM LANE	DECATUR	136-S012	24	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM MANHOLE	SHOAL CREEK	UNNAMED	1/4/2019	14:35	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/4/2019	1/9/2019	CCTV, CLEANING WORK ORDERS COMPLETED
13	1/4/2019	10:32	N	N	7,780	1964 EAST STARMOUNT WAY	DECATUR	N/A	15	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM CLEANOUT	DOOLITTLE CREEK	UNNAMED	1/4/2019	17:01	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/4/2019	1/9/2019	CCTV, CLEANING WORK ORDERS COMPLETED
14	1/4/2019	10:38	N	Y	10,000	314 HATTON DRIVE	SCOTSDALE	011-S207	10	GR	GREASE BLOCKED THE 10(IN) SEWER MAIN	INDIAN CREEK	UNNAMED	1/4/2019	12:15	PRESSURE WASHED 10(IN) SEWER MAIN 350(FT) AND CLEARED THE GREASE BLOCKAGE AT 125(FT) TO RESTORE THE NORMAL FLOW	1/4/2019	1/9/2019	CCTV, CLEANING WORK ORDERS COMPLETED
15	1/4/2019	11:25	N	N	9,000	2223 PINWOOD DRIVE	DECATUR	N/A	8	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM CLEANOUT	DOOLITTLE CREEK	UNNAMED	1/4/2019	13:55	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/4/2019	1/9/2019	CCTV, CLEANING WORK ORDERS COMPLETED
16	1/4/2019	16:25	N	N	2,500	120 BROWER STREET	DECATUR	214-S099	8	UNK	UNKNOWN BLOCKAGE ON SEWER MAIN	SHOAL CREEK	WEST	1/4/2019	18:30	PRESSURE WASHED 8(IN) SEWER MAIN AND CLEARED THE UNKNOWN BLOCKAGE AT 75(FT) TO RESTORE THE NORMAL FLOW	1/4/2019	1/9/2019	CCTV, CLEANING WORK ORDERS COMPLETED
17	1/5/2019	12:54	N	N	1,120	4000 DUNWOODY PARK	DUNWOODY	345-S104	8	GR	GREASE BLOCKED THE 8(IN) SEWER MAIN	NANCY CREEK	UNNAMED	1/5/2019	13:50	PRESSURE WASHED 8(IN) SEWER MAIN AND CLEARED THE UNKNOWN BLOCKAGE AT 127(FT) TO RESTORE THE NORMAL FLOW	1/5/2019	1/9/2019	CCTV, FOG EDUCATION AND CLEANING WORK ORDERS COMPLETED
18	1/6/2019	11:26	N	N	200	4880 HAMMERMILL ROAD	TUCKER	184-S018	8	GR	GREASE BLOCKED THE 8(IN) SEWER MAIN	STONE MOUNTAIN CREEK	UNNAMED	1/6/2019	11:29	PRESSURE WASHED 8(IN) SEWER MAIN AND CLEARED THE GREASE BLOCKAGE AT 17(FT) TO RESTORE THE NORMAL FLOW	1/6/2019	1/9/2019	CCTV, FOG EDUCATION AND CLEANING WORK ORDERS COMPLETED
19	1/7/2019	10:27	N	N	6,150	5726 SOUTHLAND DRIVE	STONE MTN	065-S004	8	GR	GREASE BLOCKED THE 8(IN) SEWER MAIN	NORTH CROOKED CREEK	UNNAMED	1/7/2019	12:30	PRESSURE WASHED 8(IN) SEWER MAIN AND CLEARED THE GREASE BLOCKAGE AT 244(FT) TO RESTORE THE NORMAL FLOW	1/7/2019	1/9/2019	CCTV, FOG EDUCATION AND CLEANING WORK ORDERS COMPLETED
20	1/14/2019	9:13	N	Y	14,520	3792 HARVEST DRIVE	DECATUR	060-S041	8	GR/DB	GREASE AND DEBRIS BLOCKED THE 8(IN) SEWER MAIN	SOUTH RIVER	UNNAMED	1/14/2019	13:15	PRESSURE WASHED 8(IN) SEWER MAIN 400(FT) AND CLEARED THE GREASE/DEBRIS(WIPES) BLOCKAGE AT 374(FT) TO RESTORE THE NORMAL FLOW	1/14/2019	1/17/2019	CCTV, FOG EDUCATION AND CLEANING WORK ORDERS COMPLETED
21	1/14/2019	17:24	N	Y	76,440	4900 CENTRAL DRIVE	STONE MTN	124-S016,S017	12	DB	DEBRIS BLOCKED THE 12(IN) SEWER MAIN	SNAPPINGER CREEK	UNNAMED	1/14/2019	18:55	PRESSURE WASHED 12(IN) SEWER MAIN 210(FT) AND CLEARED THE DEBRIS(WOOD) BLOCKAGE AT 200(FT) TO RESTORE THE NORMAL FLOW	1/15/2019	1/17/2019	CCTV, FOG EDUCATION AND CLEANING WORK ORDERS COMPLETED
22	1/16/2019	9:46	N	N	9,840	6648 PEACHTREE INDUSTRIAL BLVD	DORAVILLE	356-S103	8	GR	GREASE BLOCKED THE 8(IN) SEWER MAIN	NANCY CREEK	UNNAMED	1/16/2019	12:30	PRESSURE WASHED 8(IN) SEWER MAIN AND CLEARED THE GREASE BLOCKAGE AT 170(FT) TO RESTORE THE NORMAL FLOW	1/16/2019	1/18/2019	CCTV, FOG EDUCATION AND CLEANING WORK ORDERS COMPLETED

**DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet -- 1st Quarter Report 2019**

**Spills**

Spill No.	Date/Time		Type & Volume			Location		MH/pipe		Cause/Source		Water Body		Flow Restoration				Notifications		
	Date Spill Reported to DWM	Time Spill Reported to DWM	Fish Kill	Major Spill	Estimated Quantity, gals	Address of Spill	City	Manhole / Structure #	Pipe Size	Cause	Source	Receiving Stream or Waterbody	Tributary	Restoration Date	Restoration Time	Flow Restoration Action	24 hour Notice	5 Day Letter	Additional Follow-up	
23	1/22/2019(spill date 1/19/19)	12:09(18:00)	N	N	719	1615 MELANIE COURT	DECATUR	184-S004	18	I&I	FOUND EVIDENCE THAT MANHOLE SPILLED DUE TO I&I FROM STORM EVENT. EVENT CONFIRMED BY FLOW MONITORING DATA	SHOAL CREEK	UNNAMED	1/19/2019	19:00	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/22/2019	1/24/2019	CCTV, FOG EDUCATION AND CLEANING WORK ORDERS COMPLETED	
24	1/22/2019(spill date 1/20/19)	13:23(09:15)	N	Y	23,564	3230 BORING ROAD	DECATUR	070-S016	30	I&I	FOUND EVIDENCE THAT MANHOLE SPILLED DUE TO I&I FROM STORM EVENT. EVENT CONFIRMED BY FLOW MONITORING DATA	SHOAL CREEK	UNNAMED	1/19/2019	0:15	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/22/2019	1/24/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
25	1/24/2019	12:41(12:15)	N	Y	37,853	3230 BORING ROAD	DECATUR	070-S016	30	I&I	FOUND EVIDENCE THAT MANHOLE SPILLED DUE TO I&I FROM STORM EVENT. EVENT CONFIRMED BY FLOW MONITORING DATA	SHOAL CREEK	UNNAMED	1/24/2019	12:30	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/24/2019	1/28/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
26	1/24/2019	17:50	N	Y	22,500	3449 BROOKFIELD LANE	DECATUR	N/A	6	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM CLEANOUT	COBBS CREEK	N/A	1/24/2019	10:00	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/24/2019	1/28/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
27	1/24/2019	21:08(00:15)	N	Y	216,000	4347 FLAT SHOALS PARKWAY	DECATUR	070-S015 & S050	36	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM MANHOLE	SHOAL CREEK	N/A	1/24/2019	12:15	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/24/2019	1/28/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
28	1/24/2019(spill date 1/23/19)	21:46(20:00)	N	Y	11,570	1615 MELANIE COURT	DECATUR	184-S004	24	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM MANHOLE	SHOAL CREEK	N/A	1/24/2019	1:15	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/24/2019	1/28/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
29	1/24/2019	2:15	N	Y	34,050	4557 MEADOW CREEK PATH	LITHONIA	034-S090	54	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM MANHOLE	SNAPPINGER CREEK	N/A	1/24/2019	9:15	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/24/2019	1/28/2019	CCTV, CLEANING WORK ORDERS COMPLETED BY THE CONTRACTORS	
30	1/25/2019	9:09	N	N	4,545	2712 NORTH DECATUR ROAD	DECATUR	049-S038, S039	8	DB	DEBRIS BLOCKED THE 8(IN) SEWER MAIN	SOUTH FORK PEACHTREE CREEK	UNNAMED	1/25/2019	10:50	PRESSURE WASHED 8(IN) SEWER MAIN 300(FT) AND CLEARED THE DEBRIS(RAGS) BLOCKAGE AT 160(FT) TO RESTORE THE NORMAL FLOW	1/25/2019	1/28/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
31	1/25/2019	14:05	N	N	70	3047 GLENDALE COURT	DECATUR	153-S070	8	I&I	FOUND EVIDENCE THAT MANHOLE SPILLED DUE TO I&I FROM STORM EVENT	SHOAL CREEK	UNNAMED	1/25/2019	14:30	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	1/25/2019	1/28/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
32	1/25/2019	16:00	N	N	1,840	100 DERING CIRCLE	ATLANTA	235-S310	8	DB	DEBRIS BLOCKED THE 8(IN) SEWER MAIN	NORTH FORK PEACHTREE CREEK	B	1/25/2019	16:46	RODDED THE 8(IN) SEWER MAIN 70(FT) AND CLEARED THE DEBRIS(RAGS) BLOCKAGE AT 30(FT) TO RESTORE THE NORMAL FLOW	1/25/2019	1/28/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
33	1/27/2019	14:03	N	N	700	2154 DERING CIRCLE	ATLANTA	235-S022	8	DB	DEBRIS BLOCKED THE 8(IN) SEWER MAIN	NORTH FORK PEACHTREE CREEK	B	1/27/2019	14:38	PRESSURE WASHED 8(IN) SEWER MAIN 23(FT) AND CLEARED THE DEBRIS(RAGS) BLOCKAGE AT 21(FT) TO RESTORE THE NORMAL FLOW	1/27/2019	1/30/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
34	1/28/2019	21:05	N	N	2,480	750 CARLISLE CLUB DRIVE	STONE MTN	254-S087	8	GR	FOUND EVIDENCE THAT MANHOLE SPILLED DUE TO A GREASE BLOCKAGE ON 8(IN) SEWER MAIN	SNAPPINGER CREEK	UNNAMED	1/28/2019	22:07	PRESSURE WASHED 8(IN) SEWER MAIN 220(FT) AND CLEARED THE GREASE BLOCKAGE AT 209(FT) TO RESTORE THE NORMAL FLOW	1/29/2019	1/30/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
35	1/29/2019	12:39	N	N	4,260	541 SHERWOOD GREENS	STONE MTN	020-S052	8	GR	GREASE BLOCKED THE 8(IN) SEWER MAIN	NORTH CROOKED CREEK	UNNAMED	1/29/2019	13:50	PRESSURE WASHED 8(IN) SEWER MAIN 400(FT) AND CLEARED THE GREASE BLOCKAGE AT 325(FT) TO RESTORE THE NORMAL FLOW	1/29/2019	2/1/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
36	1/29/2019(spill date 1/25/19)	14:02(10:15)	N	Y	239,480	3149 MEMORIAL DRIVE	DECATUR	183-S023	8	GR	FOUND EVIDENCE THAT MANHOLE SPILLED DUE TO A GREASE BLOCKAGE ON 8(IN) SEWER MAIN. SPILL WAS FOUND BY SOURCE TRACKING	SHOAL CREEK	UNNAMED	1/29/2019	14:45	PRESSURE WASHED 8(IN) SEWER MAIN 340(FT) AND CLEARED THE GREASE BLOCKAGE AT 228(FT) TO RESTORE THE NORMAL FLOW	1/30/2019	2/1/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
37	1/29/2019	17:46	N	Y	12,610	5000 LONGVIEW RUN	DECATUR	009-S036	12	GR	GREASE BLOCKED THE 12(IN) SEWER MAIN	SNAPPINGER CREEK	UNNAMED	1/29/2019	19:23	RODDED THE 12(IN) SEWER MAIN AND CLEARED THE GREASE BLOCKAGE AT 135(FT) TO RESTORE THE NORMAL FLOW	1/29/2019	2/1/2019	CCTV, CLEANING AND REPLACE MANHOLE LID WORK ORDERS COMPLETED	
38	1/30/2019	10:16	N	N	2,540	2933 MILLER ROAD	DECATUR	024-S050	8	RT	ROOTS BLOCKED THE 8(IN) SEWER MAIN	SNAPPINGER CREEK	UNNAMED	1/30/2019	19:23	PRESSURE WASHED 8(IN) SEWER MAIN 200(FT) AND CLEARED THE ROOT BLOCKAGE AT 150(FT) TO RESTORE THE NORMAL FLOW	1/30/2019	2/1/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
39	1/30/2019	21:28	N	N	3,720	4843 LONGVIEW RUN	DECATUR	009-S317	8	GR	GREASE BLOCKED THE 8(IN) SEWER MAIN	SNAPPINGER CREEK	UNNAMED	1/30/2019	22:30	RODDED THE 8(IN) SEWER MAIN AND CLEARED THE GREASE BLOCKAGE AT 15(FT) TO RESTORE THE NORMAL FLOW	1/30/2019	2/1/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
40	1/31/2019	11:13	N	N	9,100	3289 MONTREAL INDUSTRIAL WAY	TUCKER	164-S009	10	BRK LN/STR	MANHOLE SPILLED DUE TO BROKEN SEWER MAIN	BURNT FORK CREEK	UNNAMED	1/31/2019	12:05	THE CONTRACTORS SETUP A BYPASS PUMP TO RESTORE FLOW UNTIL FINAL REPAIRS ARE COMPLETED	2/1/2019	2/4/2019	CCTV, CLEANING AND REPAIR WORK ORDERS COMPLETED THE REPAIR WORK WAS COMPLETED BY CONTRACTORS	
41	1/31/2019	12:36	N	N	200	2675 NORTH DECATUR ROAD	DECATUR	049-S039	8	GR	FOUND EVIDENCE THAT MANHOLE SPILLED DUE TO A GREASE BLOCKAGE ON 8(IN) SEWER MAIN	SOUTH FORK PEACHTREE CREEK	C	1/31/2019	13:10	PRESSURE WASHED 8(IN) SEWER MAIN 340(FT) AND CLEARED THE GREASE BLOCKAGE AT 56(FT) TO RESTORE THE NORMAL FLOW	1/31/2019	2/4/2019	CCTV, CLEANING AND FOG EDUCATION WORK ORDERS COMPLETED	
42	1/31/2019	13:55	N	N	3,060	2301 MOUNTAIN INDUSTRIAL BLVD	TUCKER	215-S221	8	GR	GREASE BLOCKED THE 8(IN) SEWER MAIN	CAMP CREEK	UNNAMED	1/31/2019	14:46	PRESSURE WASHED 8(IN) SEWER MAIN 23(FT) AND CLEARED THE GREASE BLOCKAGE AT 8(FT) TO RESTORE THE NORMAL FLOW	1/31/2019	2/4/2019	CCTV, CLEANING AND FOG EDUCATION WORK ORDERS COMPLETED	
43	2/1/2019	9:04	N	N	5,880	2000 CASTLEWAY DRIVE	ATLANTA	192-S103	8	RT	ROOTS BLOCKED THE 8(IN) SEWER MAIN	NORTH FORK PEACHTREE CREEK	D-2	2/1/2019	10:42	ROOT CUT 8(IN) SEWER MAIN 150(FT) AND CLEARED THE ROOT BLOCKAGE AT 100(FT) TO RESTORE THE NORMAL FLOW	2/1/2019	2/4/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	

**DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet -- 1st Quarter Report 2019**

**Spills**

Spill No.	Date/Time		Type & Volume			Location		MH/pipe		Cause/Source		Water Body		Flow Restoration				Notifications		
	Date Spill Reported to DWM	Time Spill Reported to DWM	Fish Kill	Major Spill	Estimated Quantity, gals	Address of Spill	City	Manhole / Structure #	Pipe Size	Cause	Source	Receiving Stream or Waterbody	Tributary	Restoration Date	Restoration Time	Flow Restoration Action	24 hour Notice	5 Day Letter	Additional Follow-up	
44	2/2/2019	10:30	N	N	7,200	6346 GREENOCK DRIVE	STONE MTN	N/A	8	OUTSIDE CON	CONTRACTORS BYPASS PUMP HOSE BROKE CAUSING SPILL	NORTH CROOKED CREEK	UNNAMED	2/2/2019	12:30	THE CONTRACTORS TURNED THE 10(IN) BYPASS PUMPS OFF TO STOP THE SPILL UNTIL REPAIRS WERE MADE TO THE HOSE	2/2/2019	2/6/2019	REPAIRS WERE MADE TO THE PUMP AND NO ADDITIONAL FOLLOWUPS NEEDED AT THIS SITE	
45	2/2/2019	16:47	N	N	760	3929 WEDGEFIELD CIRCLE	DECATUR	157-S033	8	DB	DEBRIS BLOCKED THE 8(IN) SEWER MAIN	FOWLER BRANCH CREEK	UNNAMED	2/2/2019	17:25	PRESSURE WASHED 8(IN) SEWER MAIN 75(FT) AND CLEARED THE DEBRIS BLOCKAGE AT 5(FT) TO RESTORE THE NORMAL FLOW	2/2/2019	2/6/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
46	2/4/2019	6:46	N	N	2,220	3831 EAST AVENUE	CLARKSTON	095-S203	8	DB	DEBRIS BLOCKED THE 8(IN) SEWER MAIN	UPPER SNAPPINGER CREEK	UNNAMED	2/4/2019	8:00	PRESSURE WASHED 8(IN) SEWER MAIN 200(FT) AND CLEARED THE DEBRIS BLOCKAGE AT 100(FT) TO RESTORE THE NORMAL FLOW	2/4/2019	2/6/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
47	2/4/2019	8:13	N	N	200	125 BEAUMONT AVENUE	DECATUR	246-S140	8	GR	GREASE BLOCKED THE 8(IN) SEWER MAIN	LAMONT DRIVE BRANCH CREEK	N/A	2/4/2019	9:05	PRESSURE WASHED 8(IN) SEWER MAIN 214(FT) AND CLEARED THE GREASE BLOCKAGE AT 204(FT) TO RESTORE THE NORMAL FLOW	2/4/2019	2/6/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
48	2/5/2019	10:15	N	Y	15,320	3486 HIDDEN ACRES DRIVE	DORAVILLE	292-S058	8	BRK LN/STR	MANHOLE SPILLED DUE TO BROKEN SEWER MAIN	NORTH PEACHTREE CREEK	C	2/5/2019	11:10	PRESSURE WASHED 8(IN) SEWER MAIN 190(FT) AND CLEARED THE BLOCKAGE AT 180(FT) TO RESTORE THE NORMAL FLOW. POINT REPAIR MADE	2/5/2019	2/6/2019	CCTV, CLEANING AND REPAIR WORK ORDERS COMPLETED	
49	2/5/2019	14:20	N	N	1,140	2996 EDNA LANE	DECATUR	153-S051	8	GR	GREASE BLOCKED THE 8(IN) SEWER MAIN	SHOAL CREEK	UNNAMED	2/5/2019	15:17	PRESSURE WASHED 8(IN) SEWER MAIN 180(FT) AND CLEARED THE GREASE BLOCKAGE AT 160(FT) TO RESTORE THE NORMAL FLOW	2/5/2019	2/6/2019	CCTV, CLEANING AND FOG EDUCATION WORK ORDERS COMPLETED	
50	2/8/2019	12:24	N	N	3,960	3532 CHERRY VIEW PLACE	DECATUR	060-S022	8	GR	GREASE BLOCKED THE 8(IN) SEWER MAIN	SOUTH RIVER	CONLEY CREEK	2/8/2019	15:42	PRESSURE WASHED 8(IN) SEWER MAIN 359(FT) AND CLEARED THE GREASE BLOCKAGE AT 11(FT) TO RESTORE THE NORMAL FLOW	2/8/2019	2/12/2019	CCTV, CLEANING AND FOG EDUCATION WORK ORDERS COMPLETED	
51	2/15/2019	18:33	N	N	2,400	50 EXECUTIVE PARK SOUTH	ATLANTA	154-S103	8	DB	FOUND EVIDENCE THAT MANHOLE SPILLED DUE TO A DEBRIS(RAGS) BLOCKAGE	NORTH FORK PEACHTREE CREEK	UNNAMED	2/15/2019	19:33	PRESSURE WASHED 8(IN) SEWER MAIN 298(FT) AND CLEARED THE DEBRIS(RAGS) BLOCKAGE AT 291(FT) TO RESTORE THE NORMAL FLOW	2/15/2019	2/15/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
52	2/19/2019	14:15	N	N	1,500	1615 MELANIE COURT	DECATUR	184-S004 AND 184-S002	21	I&I/PUMP FLR	I&I FROM STORM EVENT CAUSED SPILL FROM MANHOLE. SITE WAS BYPASS PUMPING AND FLOW OVERWHELMED PUMP	SHOAL CREEK	UNNAMED	2/19/2019	14:30	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	2/20/2019	2/21/2019	CCTV AND CLEANING WORK ORDERS COMPLETED BY THE CONTRACTORS	
53	2/21/2019	2:30	N	N	4,400	3230 BORING ROAD	DECATUR	070-S016	30	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM MANHOLE	SHOAL CREEK	N/A	2/21/2019	4:00	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	2/21/2019	2/25/2019	CCTV AND CLEANING WORK ORDERS COMPLETED BY THE CONTRACTORS	
54	2/25/2019	13:35	N	N	1,500	792 JOLLY AVENUE SOUTH	CLARKSTON	N/A	4	BRK LN/STR	CLEANOUT SPILLED DUE TO BROKEN SEWER MAIN	INDIAN CREEK	UNNAMED	2/25/2019	22:16	TO STOP THE SPILL THE WATER WAS TURNED OFF TO THAT PARTICULAR BUILDING UNTIL FINAL REPAIRS WERE MADE. THE REPAIRS WERE COMPLETED ON 2/27/19	2/25/2019	3/1/2019	CCTV, CLEANING AND REPAIR WORK ORDERS COMPLETED	
55	2/26/2019	15:22	N	N	25	3621 GREENTREE FARMS DRIVE	DECATUR	N/A	4	BRK LN/STR	CLEANOUT SPILLED DUE TO BROKEN SEWER MAIN	COBBS CREEK	UNNAMED	2/26/2019	15:55	RODDED THE 4(IN) ROW CLEANOUT 219FT) AND CLEARED THE BLOCKAGE AT 21(FT) TO RESTORE THE NORMAL FLOW	2/27/2019	3/1/2019	CCTV, CLEANING AND REPAIR WORK ORDERS COMPLETED	
56	2/27/2019	17:24	N	N	820	3949 HARTS MILL LANE	ATLANTA	N/A	6	RT	ROOTS BLOCKED THE 8(IN) SEWER MAIN	NANCY CREEK	N/A	2/27/2019	18:05	RODDED THE 6(IN) ROW CLEANOUT 30(FT) AND CLEARED THE ROOT BLOCKAGE AT 15(FT) TO RESTORE THE NORMAL FLOW	2/27/2019	3/1/2019	CCTV, CLEANING AND REPAIR WORK ORDERS COMPLETED	
57	2/28/2019	17:32	N	N	3,320	3540 BUFORD HIGHWAY	ATLANTA	202-S113	8	GR	GREASE BLOCKED THE 8(IN) SEWER MAIN	NORTH FORK PEACHTREE CREEK	N/A	2/28/2019	18:55	PRESSURE WASHED 8(IN) SEWER MAIN 225(FT) AND CLEARED THE GREASE BLOCKAGE AT 180(FT) TO RESTORE THE NORMAL FLOW	2/28/2019	3/1/2019	CCTV, CLEANING AND FOG EDUCATION WORK ORDERS COMPLETED	
58	3/1/2019	14:24	N	N	5,720	3311 PANTHERSVILLE ROAD	DECATUR	N/A	8	BRK LN/STR/TREE	FOUND BROKEN CREEK CROSSING SPILLING INTO SOUTH RIVER DUE TO A FALLEN TREE.	SOUTH RIVER	N/A	3/1/2019	19:10	BUILT A BERM TO CONTAIN THE SEWER SPILL UNTIL THE FINAL REPAIRS WERE COMPLETED ON 3/2/19	3/2/2019	3/6/2019	CCTV, CLEANING AND REPAIR WORK ORDERS COMPLETED	
59	3/3/2019	16:28	N	N	3,394	1615 MELANIE COURT	DECATUR	184-S004	21	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM MANHOLE	SHOAL CREEK	UNNAMED	3/3/2019	17:30	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE. THE BYPASS PUMP WAS OVERWHELMED BY THE FLOW	3/3/2019	3/7/2019	CCTV AND CLEANING WORK ORDERS COMPLETED BY THE CONTRACTORS	
60	3/3/2019	16:30	N	N	6,750	608 SOUTH MCDONOUGH STREET	DECATUR	214-S013	8	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM MANHOLE	SHOAL CREEK	WEST	3/3/2019	17:15	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	3/4/2019	3/7/2019	CCTV AND CLEANING WORK ORDERS COMPLETED BY THE CONTRACTORS	
61	3/3/2019	16:30	N	N	6,500	2052 GRAND PRIX DRIVE	ATLANTA	193-S086	10	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM MANHOLE	NORTH FORK PEACHTREE CREEK	D-2	3/3/2019	18:40	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	3/4/2019	3/7/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
62	3/3/2019	16:36	N	N	575	307 2ND AVENUE	DECATUR	213-S201	10	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM MANHOLE	SUGAR CREEK	A	3/3/2019	16:59	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	3/3/2019	3/7/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
63	3/3/2019	17:04	N	N	2,530	3449 BROOKFIELD LANE	DECATUR	N/A	4	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM CLEANOUT	COBBS CREEK	N/A	3/3/2019	21:17	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	3/4/2019	3/7/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
64	3/4/2019	9:53	N	N	400	3303 PANTHERSVILLE ROAD	DECATUR	073-S006, S007	24	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM MANHOLE	DOOLITTLE CREEK	N/A	3/4/2019	10:19	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	3/4/2019	3/7/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	
65	3/4/2019	11:04	N	N	500	4557 MEADOW CREEK PATH	LITHONIA	034-S090	54	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM MANHOLE	SNAPPINGER CREEK	N/A	3/4/2019	12:00	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	3/4/2019	3/7/2019	CCTV AND CLEANING WORK ORDERS COMPLETED	

**DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet -- 1st Quarter Report 2019**

**Spills**

Spill No.	Date/Time		Type & Volume			Location		MH/pipe		Cause/Source		Water Body		Flow Restoration			Notifications		
	Date Spill Reported to DWM	Time Spill Reported to DWM	Fish Kill	Major Spill	Estimated Quantity, gals	Address of Spill	City	Manhole / Structure #	Pipe Size	Cause	Source	Receiving Stream or Waterbody	Tributary	Restoration Date	Restoration Time	Flow Restoration Action	24 hour Notice	5 Day Letter	Additional Follow-up
66	3/7/2019	18:38	N	N	5,760	176 WINTERSPARK DRIVE	ATLANTA	340-S009	8	GR	GREASE BLOCKED THE 8(IN) SEWER MAIN	NANCY CREEK	2	3/7/2019	20:14	PRESSURE WASHED THE 8(IN) SEWER MAIN 100(FT) AND CLEARED THE GREASE BLOCKAGE AT 90(FT) TO RESTORE THE NORMAL FLOW	3/7/2019	3/11/2019	CCTV, CLEANING AND FOG EDUCATION EDUCATION WORK ORDERS COMPLETED
67	3/10/2019	11:43	N	Y	29,432	7280 ROCKLAND ROAD	LITHONIA	N/A	30	OTH	AIR VALVE ON 30(IN) FORCE MAIN BROKE CAUSING SPILL	HONEY CREEK	N/A	3/8/2019	14:56	TECHNICIANS OPERATED THE LIFT STATION TO CONTROL FLOW AND ISOLATE THE VALVE	3/8/2019	3/14/2019 revised 4/5/2019	VALVE REPAIR WORK ORDERS COMPLETED
68	3/13/2019	12:46	N	N	5,280	1979 WOODSDALE ROAD	ATLANTA	199-S015	8	GR	GREASE BLOCKED THE 8(IN) SEWER MAIN	NORTH FORK PEACHTREE CREEK	UNNAMED	3/13/2019	14:14	PRESSURE WASHED 8(IN) SEWER MAIN 315(FT) AND CLEARED THE GREASE BLOCKAGE AT 300(FT) TO RESTORE THE NORMAL FLOW	3/14/2019	3/15/2019	CCTV, CLEANING AND FOG EDUCATION WORK ORDERS COMPLETED
69	3/18/2019	12:02	N	N	45	1901 PONCE DE LEON AVENUE	ATLANTA	N/A	4	OUTSIDE CON	A PLUMBER CAUSED A SPILL OF THE PRIVATE LATERAL	PEAVINE CREEK SOUTH FORK	N/A	3/18/2019	12:30	PLUMBER STOPPED JETTING THE LATERAL, WHICH STOPPED THE SPILL	3/19/2019	3/21/2019	CCTV AND CLEANING WORK ORDERS COMPLETED
70	3/18/2019	12:30	N	N	6,300	3806 NORTH PEACHTREE ROAD	CHAMBLEE	323-P081	15	RT	ROOTS BLOCKED THE 15(IN) SEWER MAIN	NANCY CREEK	B	3/18/2019	13:40	PRESSURE WASHED THE 15(IN) SEWER MAIN 150(FT) AND CLEARED THE ROOT BLOCKAGE AT 50(FT) TO RESTORE THE NORMAL FLOW	3/18/2019	3/21/2019	CCTV AND CLEANING WORK ORDERS COMPLETED
71	3/21/2019	16:26	N	N	2,180	401 ROLLINS WAY	ATLANTA	058-S083	8	BRK LN/STR	MANHOLE SPILLED DUE TO BROKEN SEWER MAIN	PEAVINE CREEK	N/A	3/21/2019	18:15	PRESSURE WASHED THE 8(IN) SEWER MAIN 190(FT) AND CLEARED THE BLOCKAGE AT 190(FT) TO RESTORE THE NORMAL FLOW	3/22/2019	3/22/2019	CCTV, CLEANING AND REPAIR WORK ORDERS COMPLETED
72	3/22/2019	22:44	N	Y	14,760	2890 CEDAR CREEK DRIVE	DECATUR	099-S103	8	GR	GREASE BLOCKED THE 8(IN) SEWER MAIN	SOUTH FORK PEACHTREE CREEK	UNNAMED	3/23/2019	2:50	PRESSURE WASHED THE 8(IN) SEWER MAIN 90(FT) AND CLEARED THE GREASE BLOCKAGE AT 80(FT) TO RESTORE THE NORMAL FLOW	3/23/2019	3/26/2019	CCTV, CLEANING AND FOG EDUCATION WORK ORDERS COMPLETED
73	3/23/2019	9:30	N	N	83	2161 CHESTNUT HILL CIRCLE	DECATUR	N/A	4	BRK LN/STR	A BROKEN WATER MAIN CAUSED DAMAGE TO THE PRIVATE LATERAL. SEWER WAS FLUSHED FROM THE PIPE INTO THE DRAIN	COBBS CREEK	UNNAMED	3/23/2019	13:30	CREWS REPAIRED THE 2(IN) WATER MAIN, WHICH STOPPED THE SEWER SPILL	3/23/2019	3/26/2019	CCTV, CLEANING AND REPAIR WORK ORDERS COMPLETED
74	3/25/2019	12:44	N	N	20	1618 PINE GLEN CIRCLE	DECATUR	N/A	6	UNK	UNKNOWN BLOCKAGE ON SEWER MAIN CAUSED CLEANOUT TO SPILL	SNAPPINGER CREEK	N/A	3/25/2019	15:00	RODDER THE 6(IN) ROW CLEANOUT 30(FT) AND CLEARED THE ROOT BLOCKAGE AT 15(FT) TO RESTORE THE NORMAL FLOW	3/25/2019	3/26/2019	CCTV AND CLEANING WORK ORDERS COMPLETED
75	3/26/2019	17:35	N	N	3,740	3629 SPRINGRUN DRIVE	DECATUR	N/A	8	CRK BRK	8(IN) CREEK CROSSING BROKE	COBBS CREEK	N/A	3/26/2019	22:10	INSTALLED A 2(IN) FULL CIRCLE CLAMP AND ALSO BUILT A TEMPORARY BERM TO CONTAIN THE SPILL UNTIL FINAL REPAIRS ARE COMPLETED	3/27/2019	3/29/2019	CCTV, CLEANING AND REPAIR WORK ORDERS COMPLETED
76	3/28/2019	12:49	N	N	2,460	4301 COVINGTON HIGHWAY	DECATUR	196-S050	8	GR	GREASE BLOCKED THE 8(IN) SEWER MAIN	FOWLER BRANCH CREEK	N/A	3/28/2019	13:30	PRESSURE WASHED THE 8(IN) SEWER MAIN 63(FT) AND CLEARED THE GREASE BLOCKAGE AT 60(FT) TO RESTORE THE NORMAL FLOW	3/28/2019	4/1/2019	CCTV, CLEANING AND FOG EDUCATION WORK ORDERS COMPLETED
77	3/28/2019(spill date 3/3/2019)	12:49-(16:15)	N	N	359	607 3RD AVENUE	DECATUR	213-S050	8	I&I	I&I FROM STORM EVENT CAUSED SPILL FROM MANHOLE. SPILL WAS FOUND BY SOURCE TRACKING	SUGAR CREEK	A	3/3/2019	17:15	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	3/30/2019	4/2/2019	CCTV AND CLEANING WORK ORDERS COMPLETED

Code Causes and Abbreviations	
GR	Grease
RT	Roots
DB	Debris
GRRT	Grease and Roots
GRDB	Grease and Debris
RTDB	Roots and Debris
GRRTDB	Grease, Roots and Debris
BRK LN/STR	Broken Main, Broken Line, Broken Structure
STORM	Storm Event(s)
OUTSIDE CON	Caused By Third Party/Contractor
MH	Manhole Issue/Damage
VAND	Vandalism
OTH	Other
CC	County Contractor
HO	Homeowner improvement
CV	Missing Check Valve



**DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet**

**Overflows**

Overflow No.	Date/Time		Quantity in Gallons	Location		Cause/Source		Flow Restoration			Results
	Date Overflow Reported to DWM	Time Overflow Reported to DWM		Address of Overflow	City	Cause	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Action	Additional Follow-up
1	1/4/2019	17:12	200	1970 EAST STARMOUNT WAY	DECATUR	I&I	FOUND 6(INI) ROW CLEANOUT THAT HAD OVERFLOWED DUE TO I&I FROM HEAVY RAIN EVENT	1/4/2019	17:35	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	CCTV AND CLEANING WORK ORDERS COMPLETED
2	1/8/2019	10:05	5	611 3RD AVENUE	DECATUR	DB	FOUND MANHOLE WITH EVIDENCE OF A RECENT OVERFLOW DUE TO DEBRIS BLOCKAGE	1/8/2019	10:40	CLEANED UP DEBRIS AND PUT OUT DISINFECTANT AROUND THE MANHOLE AREA	CCTV AND CLEANING WORK ORDERS COMPLETED
3	1/18/2019	8:57	20	4526 DORSET CIRCLE	DECATUR	GR	FOUND MANHOLE #15-130-S300 THAT HAD PREVIOUSLY OVERFLOWED DUE TO A GREASE BLOCKAGE	1/18/2019	9:25	RODDED FROM THE MANHOLE 36(FT) TO CLEAR THE BLOCKAGE AT 2(FT) TO RESTORE FLOW	CCTV AND CLEANING WORK ORDERS COMPLETED
4	1/19/2019	13:49	200	1912 BROCKETT ROAD	TUCKER	RT	FOUND 4(IN) ROW CLEANOUT THAT HAD PREVIOUSLY OVERFLOWED DUE TO A ROOT BLOCKAGE IN THE 8(IN) SEWER MAIN	1/19/2019	14:15	PRESSURE WASHED THE 8(IN) MAIN 175(FT) TO CLEAR THE BLOCKAGE AT 175(FT) WHICH RESTORED THE FLOW	CCTV AND CLEANING WORK ORDERS COMPLETED
5	1/23/2019	15:38	5	3575 MCCALL PLACE	DORAVILLE	BRK LN/STR	FOUND 4(IN) ROW CLEANOUT THAT HAD PREVIOUSLY OVERFLOWED DUE TO A BROKEN 8(IN) SEWER MAIN	1/23/2019	16:31	PRESSURE WASHED THE 8(IN) MAIN 300(FT) TO CLEAR THE BLOCKAGE AT 150(FT) WHICH RESTORED THE FLOW. ALSO A POINT REPAIR WAS COMPLETED ON THE 8(IN) MAIN	CCTV, REPAIR AND CLEANING WORK ORDERS COMPLETED
6	1/25/2019	15:41	50	2056 DESMOND DRIVE	DECATUR	I&I	FOUND A HOLE ON SEWER MAIN WHERE SEWER HAD ESCAPED FROM A PREVIOUS RAIN EVENT	1/25/2019	16:00	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	CCTV, REPAIR AND CLEANING WORK ORDERS COMPLETED
7	1/27/2019	20:30	50	523 PINE DRIVE	PINE LAKE	GR	FOUND STACK PIPE ON SIDE OF HOUSE OVERFLOWING DUE TO GREASE BLOCKAGE ON 8(IN) SEWER MAIN	1/27/2019	21:35	PRESSURE WASHED THE 8(IN) MAIN 200(FT) TO CLEAR THE GREASE BLOCKAGE AT 190(FT) WHICH RESTORED THE FLOW	CCTV AND CLEANING WORK ORDERS COMPLETED
8	1/28/2019	15:14	200	5374 RIDGE FOREST DRIVE	STONE MTN	OUTSIDE CON	FOUND 4(IN) CLEANOUT OVERFLOWING DUE TO THE CONTRATORS DAMAGED THE SEWER LATERAL	1/28/2019	16:56	USED HYDROVAC TO REMOVE SEWER FROM THE HOLE. LATERAL REPAIRED BY CONTRACTOR	CLEANING AND POINT REPAIR WORK ORDERS COMPLETED
9	1/31/2019	15:01	50	3037 TONEY DRIVE	DECATUR	OTH	FOUND A MANHOLE THAT HAD PREVIOUSLY OVERFLOWED. FLOW MONITORING DATA CONFIRMED	1/31/2019	15:24	CLEANED UP DEBRIS AND PUT OUT DISINFECTANT AROUND THE MANHOLE AREA	CCTV AND CLEANING WORK ORDERS COMPLETED
10	2/5/2019	11:36	50	149 NORMS STREET	DECATUR	DB	FOUND A MANHOLE THAT HAD PREVIOUSLY OVERFLOWED DUE TO HEAVY DEBRIS IN THE MANHOLE	2/5/2019	12:15	CLEANED UP DEBRIS AND PUT OUT DISINFECTANT AROUND THE MANHOLE AREA	CCTV AND CLEANING WORK ORDERS COMPLETED
11	2/6/2019	13:41	25	1445 OLDFIELD ROAD	DECATUR	UNK	FOUND A MANHOLE THAT HAD PREVIOUSLY OVERFLOWED DUE TO A UNKNOWN ISSUE	2/6/2019	14:15	CLEANED UP DEBRIS AND PUT OUT DISINFECTANT AROUND THE MANHOLE AREA	CCTV AND CLEANING WORK ORDERS COMPLETED

**DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet**

**Overflows**

Overflow No.	Date/Time		Quantity in Gallons	Location		Cause/Source		Flow Restoration			Results
	Date Overflow Reported to DWM	Time Overflow Reported to DWM		Address of Overflow	City	Cause	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Action	Additional Follow-up
12	2/16/2019	18:35	200	2553 MONTEZUMA CIRCLE	ELLENWOOD	GRRT	A 4(IN) CLEANOUT OVERFLOWED DUE TO GREASE AND ROOTS BLOCKAGE	2/16/2019	14:15	PRESSURE WASHED THE 8(IN) MAIN 70(FEET) TO REMOVE THE GREASE AND ROOT BLOCKAGE AND RESTORE FLOW	CCTV, FOG EDUCATION AND CLEANING WORK ORDERS COMPLETED
13	2/19/2019	14:18	50	1078 BEECH HAVEN ROAD	ATLANTA	I&I	FOUND A MANHOLE THAT HAD PREVIOUSLY OVERFLOWED DUE TO I&I FROM HEAVY RAIN EVENT	2/19/2019	14:46	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	CCTV AND CLEANING WORK ORDERS COMPLETED
14	2/19/2019	14:33	100	2052 GRAND PRIX DRIVE	ATLANTA	I&I	FOUND A MANHOLE THAT HAD PREVIOUSLY OVERFLOWED DUE TO I&I FROM HEAVY RAIN EVENT	2/19/2019	14:55	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	CCTV AND CLEANING WORK ORDERS COMPLETED
15	2/19/2019	15:14	90	1707 CHILDERLEE LANE	ATLANTA	I&I	FOUND A MANHOLE THAT HAD PREVIOUSLY OVERFLOWED DUE TO I&I FROM HEAVY RAIN EVENT	2/19/2019	15:50	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	CCTV AND CLEANING WORK ORDERS COMPLETED
16	2/21/2019	10:18	30	2562 TILLY MILL ROAD	DORAVILLE	I&I	FOUND A MANHOLE THAT HAD PREVIOUSLY OVERFLOWED DUE TO I&I FROM HEAVY RAIN EVENT	2/21/2019	10:58	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	CCTV AND CLEANING WORK ORDERS COMPLETED
17	2/25/2019	13:01	5	3405 RIVERVIEW CHASE WAY	ELLENWOOD	UNK	FOUND A CLEANOUT OVERFLOWING DUE TO UNKNOWN BLOCKAGE	2/25/2019	14:40	PRESSURE WASHED THE 8(IN) MAIN TO REMOVE THE UNKNOWN BLOCKAGE TO RESTORE FLOW	CCTV AND CLEANING WORK ORDERS COMPLETED
18	3/1/2019	17:18	100	3251 PANTHERSVILLE ROAD	DECATUR	I&I	FOUND A MANHOLE THAT HAD PREVIOUSLY OVERFLOWED DUE TO I&I FROM HEAVY RAIN EVENT	3/1/2019	19:10	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	CCTV AND CLEANING WORK ORDERS COMPLETED
19	3/4/2019	11:50	50	1964 EAST STARMOUNT WAY	DECATUR	I&I	FOUND 6(IN) ROW CLEANOUT THAT HAD OVERFLOWED DUE TO I&I FROM HEAVY RAIN EVENT	3/4/2019	13:30	INSPECTED UP AND DOWNSTREAM MANHOLES, WHICH WERE CLEAR AND FLOWING. CLEAN UP DEBRIS AND DISINFECTED THE AREA AROUND THE MANHOLE	CCTV AND CLEANING WORK ORDERS COMPLETED
20	3/4/2019	16:54	1,250	2200 LITHONIA INDUSTRIAL BLVD	LITHONIA	DB	FOUND MANHOLE 16-122-S250 OVERFLOWING DUE TO A DEBRIS(RAGS) BLOCKAGE	3/4/2019	18:44	PRESSURE WASHED THE 10(IN) MAIN 150(FEET) TO CLEAR THE DEBRIS BLOCKAGE AT 146(FEET) WHICH RESTORED THE FLOW	CCTV AND CLEANING WORK ORDERS COMPLETED
21	3/6/2019	13:30	10	1723 REMINGTON ROAD	CHAMBLEE	RT	FOUND EVIDENCE THAT MANHOLE 18-325-S066 HAD PREVIOUSLY OVERFLOWED DUE TO A ROOT BLOCKAGE	3/6/2019	13:45	PRESSURE WASHED THE 8(IN) SEWER MAIN 324(FEET) TO CLEAR THE ROOT BLOCKAGE AT 200(FEET) WHICH RESTORED THE FLOW	CCTV AND CLEANING WORK ORDERS COMPLETED
22	3/8/2019	11:36	10	4911 WIND COVE COURT	STONE MTN	UNK	FOUND SEWER ESCAPING FROM AROUND THE CONE OF THE MANHOLE 16-002-S042	3/8/2019	12:15	PRESSURE WASHED THE 8(IN) MAIN 200(FEET) TO CLEAR THE BLOCKAGE AT 150(FEET) WHICH RESTORED THE FLOW	CCTV AND CLEANING WORK ORDERS COMPLETED



**DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet**

**Overflows**

Overflow No.	Date/Time		Quantity in Gallons	Location		Cause/Source		Flow Restoration			Results
	Date Overflow Reported to DWM	Time Overflow Reported to DWM		Address of Overflow	City	Cause	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Action	Additional Follow-up
23	3/20/2019	16:50	500	5404 PEACHTREE ROAD	CHAMBLEE	GR	FOUND EVIDENCE THAT MANHOLE 18-229-S034 HAD PREVIOUSLY OVERFLOWED DUE TO A GREASE BLOCKAGE	3/20/2019	17:15	PRESSURE WASHED THE MANHOLE 94(FT) CLEAR THE GREASE BLOCKAGE AT 80(FT) WHICH RESTORED THE FLOW	CCTV, FOG EDUCATION AND CLEANING WORK ORDERS COMPLETED
24	3/21/2019	16:01	100	898 CLUBHOUSE CIRCLE	DECATUR	GR	FOUND MANHOLE 15-230-s034 OVERFLOWING DUE TO GREASE BLOCKAGE	3/21/2019	16:30	PRESSURE WASHED 8(IN) SEWER MAIN TO RESTORE FLOW	CCTV, FOG EDUCATION AND CLEANING WORK ORDERS COMPLETED
25	3/24/2019	14:07	30	3684 DOROCO DRIVE	DORAVILLE	UNK	FOUND MANHOLE OVERFLOWING DUE TO UNKNOWN BLOCKAGE	3/24/2019	15:00	PRESSURE WASHED MAIN FROM MH18-263-s204 UPSTREAM 30(FT) RESTORING FLOW	CCTV AND CLEANING WORK ORDERS COMPLETED
26	3/25/2019	9:17	5,720	4700 GLENWOOD ROAD	DECATUR	GR	FOUND MH 15-164-s141 OVERFLOWING DUE TO GREASE BLOCKAGE	3/25/2019	11:40	PRESSURE WASHED THE 8(IN) MAIN 100(FT) TO CLEAR THE BLOCKAGE AT 80(FT) WHICH RESTORED THE FLOW	CCTV, FOG EDUCATION AND CLEANING WORK ORDERS COMPLETED
27	3/28/2019	12:29	20	607 3RD AVENUE	DECATUR	DB	FOUND MANHOLE WITH EVIDENCE OF A RECENT OVERFLOW DUE TO DEBRIS BLOCKAGE	3/28/2019	14:30	CLEANED UP DEBRIS AND PUT OUT DISINFECTANT AROUND THE MANHOLE AREA	CCTV AND CLEANING WORK ORDERS COMPLETED
28	3/30/2019	20:08	300	3863 SNAPPINGER ROAD	LITHONIA	RT	FOUND EVIDENCE THAT MANHOLE 15-033-s030 HAD PREVIOUSLY OVERFLOWED DUE TO A ROOT BLOCKAGE	3/30/2019	20:28	PRESSURE WASHED THE 8(IN) MAIN 181(FT) TO CLEAR THE BLOCKAGE AT 168(FT) WHICH RESTORED THE FLOW	CCTV AND CLEANING WORK ORDERS COMPLETED



## DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet

### Building Back-ups

Building Back-up No.	Date/Time		Quantity in Gallons (est.)	Location		Cause/Source		Flow Restoration		
	Date Building Back-up Reported to DWM	Time Building Back-up Reported to DWM		Address of Building Back-up	City	Cause	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Action
1	1/18/2019	14:55	20	1711 CANDLER ROAD	DECATUR	ROW/LI	FOUND 6(IN) ROW CLEANOUT ON A DUAL CONECTION SURCHARGING DUE TO LATERAL ISSUES IN THE ROW. THIS CAUSED A BUILDING BACKUP	1/18/2019	16:00	THE COUNTY COMPLETED A ROW/LI POINT REPAIR, WHICH RESTORED NROMAL FLOW
2	2/14/2019	16:08	1	1583 KNOB HILL DRIVE	ATLANTA	ROW/LI	FOUND SEWER INSIDE THE HOME DUE TO A 6(IN) ROW CLEANOUT DAMAGED	2/14/2019	17:32	RODDED THE 6(IN) ROW CLEANOUT 30(FEET) AND CLEARED THE BLOCKAGE AT 16(FEET), WHICH RESTORE THE FLOW. POINT REPAIR COMPLETED
3	2/23/2019	12:59	30	1811 ALDERBROOK ROAD	ATLANTA	DB	FOUND MANHOLE 18-159-S302 SURCHARGING ON AN 8(IN) SEWER MAIN CAUSING A BUILDING BACKUP	2/23/2019	13:50	RODDED THE 8(IN) SEWER MAIN 3(FEET) AND CLEARED THE BLOCKAGE AT 3(FEET), WHICH RESTORED THE FLOW
4	2/25/2019	19:29	100	3028 WESLOCK CIRCLE	DECATUR	RT	DEKALB CREW RESPONDED TO BACKUP IN 2018, HOMEOWNER NOTIFIED WATERSHED OF BACKUP OCCURRING THAT WAS NOT PREVIOUSLY REPORTED	10/23/2018; 10/31/2018	20:35	CREW RODDED MAIN TO REMOVE ROOTS AND REPLACED SECTION OF LATERAL IN OCTOBER 2018. NO ACTIONS TAKEN IN FEBRUARY 2019 BECAUSE HOMEOWNER CLEANED UP BACKUP IN 2018
5	3/4/2019	16:47	150	2850 CRAVEY TRAIL	ATLANTA	RT	ROOT BLOCKAGE CAUSED BUILDING BACKUP	3/12/2019	17:30	REPAIRED LOWER LATERAL TO RESTORE FLOW
6	3/6/2019	18:30	20	2017 CASTLEWAY LANE	ATLANTA	ROW/LI	FOUND 4(IN) CLEANOUT SURCHARGING CAUSING A BUILDING BACKUP DUE TO LATERAL ISSUES	3/6/2019	19:05	RODDED THE 4(IN) ROW CLEANOUT 30(FEET) AND CLEARED THE BLOCKAGE AT 15(FEET), WHICH RESTORED THE FLOW
7	3/14/2019	10:56	40	466 BURLINGTON ROAD	ATLANTA	UNK	FOUND 8(IN) SEWER MAIN SURCHARGING DUE TO UNKNOWN BLOCKAGE, CAUSING BACKUP	3/14/2019	11:40	PRESSURE WASHED MAIN 60(FEET) TO CLEAR BLOCKAGE AT 25(FEET) AND RESTORE FLOW
8	3/22/2019	19:40	100	2161 CHESTNUT CIRCLE	DECATUR	BRK LN/STR	WATER MAIN CAUSED LATERAL TO BACK UP INTO BUILDING	3/23/2019	1:15	REPAIRED/REPLACED 56(FEET) PORTION OF BROKEN ROW C/O, RESTORING FLOW

## DeKalb County Department of Watershed Management

### Lateral Related Issues\*

Lateral Issue No.	Date/Time		Location			Cause/Source	Flow Restoration		
	Date Reported to DWM	Time Reported to DWM	Address	Is the WCTS main flowing without blockage?	Is there a blockage in the lower lateral?	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Actions
1	1/1/2019	2:10	3042 CATALINA DRIVE, DECATUR	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	1/1/2019	2:25	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
2	1/2/2019	7:00	596 NORTH SUPERIOR AVENUE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/2/2019	9:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
3	1/2/2019	12:30	2111 GREEN FORREST DRIVE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/2/2019	4:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
4	1/2/2019	11:30	2910 CRAVEY DRIVE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/3/2019	1:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
5	1/4/2019	3:00	1026 BRAMWELL LANE, STONE MOUNTAIN	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	1/4/2019	3:30	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
6	1/4/2019	3:30	2503 SHERBROOKE DRIVE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/4/2019	4:15	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
7	1/4/2019	5:15	6713 BROWNS MILL FERRY DRIVE, LITHONIA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/4/2019	6:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
8	1/5/2019	12:00	2529 LAUDERDALE DRIVE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/5/2019	1:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
9	1/5/2019	12:45	3929 WOOD PATH LANE, STONE MOUNTAIN	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	1/5/2019	1:00	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
10	1/6/2019	11:30	1727 BRANDYWINE COURT, DUNWOODY	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/6/2019	12:45	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
11	1/7/2019	8:40	3022 WILSON ROAD, DECATUR	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	1/7/2019	9:10	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
12	1/7/2019	3:15	2687 REDDING ROAD, ATLANTA	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	1/7/2019	3:45	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
13	1/8/2019	1:00	3670 CREEKVIEW CIRCLE, STONE MOUNTAIN	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/8/2019	2:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
14	1/9/2019	7:00	1187 DELEON COURT, CLARKSTON	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/9/2019	12:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
15	1/9/2019	4:35	4166 CEDAR KNOLL DRIVE, TUCKER	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/9/2019	4:55	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW

## DeKalb County Department of Watershed Management

### Lateral Related Issues\*

Lateral Issue No.	Date/Time		Location		Cause/Source		Flow Restoration		
	Date Reported to DWM	Time Reported to DWM	Address	Is the WCTS main flowing without blockage?	Is there a blockage in the lower lateral?	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Actions
16	1/9/2019	5:45	2487 DREW VALLEY ROAD, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/9/2019	6:45	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
17	1/10/2019	2:00	1584 CLAIRMONT LANE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/10/2019	3:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
18	1/10/2019	3:15	5999 NEW PEACHTREE ROAD, DORAVILLE	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/10/2019	4:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
19	1/12/2019	9:50	4070 CREEK COURT, STONE MOUNTAIN	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	1/12/2019	10:20	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
20	1/15/2019	11:15	1934 GLEN ECHO DRIVE, DECATUR	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	1/15/2019	11:30	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
21	1/15/2019	10:30	809 MARTIN ROAD, STONE MOUNTAIN	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/15/2019	11:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
22	1/15/2019	4:00	803 MURPHEY STREET, SCOTSDALE	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/15/2019	5:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
23	1/17/2019	9:35	2014 SILVASTONE DRIVE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/17/2019	10:05	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
24	1/17/2019	5:20	1470 CEDAR HEIGHTS DRIVE, STONE MOUNTAIN	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/17/2019	7:20	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
25	1/18/2019	11:30	253 VICKERS DRIVE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/18/2019	12:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
26	1/18/2019	3:00	1711 CANDLER ROAD, DECATUR	No	Yes	THERE WAS AN ISSUE IN BOTH THE WCTS AND THE LATERAL	1/18/2019	5:00	BLOCKAGES REMOVED FROM WCTS AND LATERAL TO RESTORE FLOW
27	1/18/2019	5:10	4931 VERMACK ROAD, DUNWOODY	No	Yes	THERE WAS AN ISSUE IN BOTH THE WCTS AND THE LATERAL	1/18/2019	6:30	BLOCKAGES REMOVED FROM WCTS AND LATERAL TO RESTORE FLOW
28	1/19/2019	3:30	5141 TILLY MILL ROAD, DUNWOODY	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/19/2019	4:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
29	1/19/2019	5:30	4519 ABRAM WAY, CONLEY	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/19/2019	8:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
30	1/21/2019	7:00	892 ASBURY WAY, LITHONIA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/21/2019	11:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW

## DeKalb County Department of Watershed Management

### Lateral Related Issues\*

Lateral Issue No.	Date/Time		Location			Cause/Source	Flow Restoration		
	Date Reported to DWM	Time Reported to DWM	Address	Is the WCTS main flowing without blockage?	Is there a blockage in the lower lateral?	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Actions
31	1/21/2019	12:10	1882 BURNING TREE DRIVE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/21/2019	1:10	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
32	1/21/2019	2:00	2257 STREET DE VILLE, ATLANTA	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	1/21/2019	3:00	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
33	1/22/2019	1:50	4664 FELLSWOOD DRIVE, STONE MOUNTAIN	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/22/2019	2:50	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
34	1/22/2019	2:30	2379 RIDGEWAY DRIVE, DORAVILLE	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/22/2019	2:50	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
35	1/22/2019	3:00	4781 LEWIS ROAD, STONE MOUNTAIN	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	1/22/2019	3:30	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
36	1/22/2019	6:45	1381 RED CEDAR TRAIL, STONE MOUNTAIN	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	1/22/2019	7:00	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
37	1/23/2019	10:00	1310 CORNWALL ROAD, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/23/2019	11:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
38	1/23/2019	12:06	5737 MILL VIEW WAY, LITHONIA	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	1/23/2019	12:21	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
39	1/23/2019	12:20	4796 HAMMERMILL ROAD, TUCKER	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/23/2019	12:35	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
40	1/23/2019	9:20	1512 MONCRIEF CIRCLE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/23/2019	10:50	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
41	1/24/2019	12:13	2014 SILVASTONE DRIVE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/24/2019	12:48	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
42	1/24/2019	7:15	2373 EWING DRIVE, ATLANTA	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	1/24/2019	7:30	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
43	1/25/2019	9:40	3304 ROMELIE DRIVE, DORAVILLE	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/25/2019	9:57	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
44	1/25/2019	7:55	4019 NORTHSTRAND DRIVE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/25/2019	8:55	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
45	1/26/2019	9:10	4111 BRENDA DRIVE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/26/2019	10:10	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW

## DeKalb County Department of Watershed Management

### Lateral Related Issues\*

Lateral Issue No.	Date/Time		Location		Cause/Source		Flow Restoration		
	Date Reported to DWM	Time Reported to DWM	Address	Is the WCTS main flowing without blockage?	Is there a blockage in the lower lateral?	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Actions
46	1/27/2019	2:20	4775 VILLAGE NORTH COURT, DUNWOODY	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/27/2019	4:20	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
47	1/27/2019	4:20	2677 VARNER DRIVE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/27/2019	5:20	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
48	1/28/2019	12:15	4338 DARWEN COURT, TUCKER	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/28/2019	1:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
49	1/28/2019	4:56	5374 RIDGE FOREST DRIVE, STONE MOUNTAIN	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/28/2019	5:11	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
50	1/29/2019	4:45	1105 HUNTINGTON PLACE CIRCLE, LITHONIA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/29/2019	6:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
51	1/30/2019	10:00	436 PRINCE OF WALES, STONE MOUNTAIN	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/30/2019	11:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
52	1/30/2019	12:15	4014 BARR CIRCLE, TUCKER	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/30/2019	12:44	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
53	1/30/2019	2:00	2845 TONEY DRIVE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/30/2019	2:45	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
54	1/30/2019	8:35	826 GREENHEDGE WAY, STONE MOUNTAIN	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/30/2019	9:20	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
55	1/31/2019	4:45	1864 LA MESA LANE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	1/31/2019	8:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
56	2/1/2019	9:45	6560 ALFORD WAY, LITHONIA	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	2/1/2019	10:15	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
57	2/1/2019	12:30	5170 MEADOWLAKE LANE, DUNWOODY	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/1/2019	1:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
58	2/1/2019	8:00	2370 CRESTA DRIVE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/1/2019	10:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
59	2/3/2019	11:10	2938 COCKLEBUR TRAIL, DECATUR	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	2/3/2019	11:20	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
60	2/3/2019	1:45	5550 RAINBOW RIDGE WAY, DECATUR	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	2/3/2019	1:55	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED



## DeKalb County Department of Watershed Management

### Lateral Related Issues\*

Lateral Issue No.	Date/Time		Location		Cause/Source		Flow Restoration		
	Date Reported to DWM	Time Reported to DWM	Address	Is the WCTS main flowing without blockage?	Is there a blockage in the lower lateral?	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Actions
61	2/4/2019	1:35	2436 STONINGTON ROAD, DUNWOODY	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/4/2019	2:35	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
62	2/5/2019	10:34	3360 HERRINGWOOD COURT	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	2/5/2019	12:00	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
63	2/6/2019	3:45	2533 FIELD SPRING DRIVE, LITHONIA	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	2/6/2019	4:00	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
64	2/7/2019	11:00	522 HICKORY HILLS DRIVE, STONE MOUNTAIN	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	2/7/2019	11:30	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
65	2/7/2019	10:10	3810 FOX GLEN COURT, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/7/2019	10:23	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
66	2/7/2019	1:23	3207 SAYBROOK DRIVE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/7/2019	1:47	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
67	2/7/2019	2:20	3563 TROUTDALE COURT	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/7/2019	3:50	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
68	2/7/2019	3:47	5186 CORNERS DRIVE, DUNWOODY	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/7/2019	4:10	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
69	2/7/2019	5:00	505 ROCKBOROUGH TERRACE, STONE MOUNTAIN	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/7/2019	6:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
70	2/7/2019	6:50	5863 GATEWAY BOULEVARD, STONE MOUNTAIN	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	2/7/2019	7:05	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
71	2/8/2019	1:58	5005 PINE BARK CIRCLE, DUNWOODY	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/8/2019	2:10	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
72	2/8/2019	3:10	1915 WOODSDALE ROAD, ATLANTA	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	2/8/2019	3:26	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
73	2/11/2019	12:55	3148 LINDMOOR DRIVE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/11/2019	1:40	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
74	2/11/2019	10:00	3743 POPLAR DRIVE, CLARKSTON	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	2/11/2019	10:15	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
75	2/12/2019	11:27	3949 HARTS MILL LANE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/12/2019	11:40	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW

## DeKalb County Department of Watershed Management

### Lateral Related Issues\*

Lateral Issue No.	Date/Time		Location		Cause/Source		Flow Restoration		
	Date Reported to DWM	Time Reported to DWM	Address	Is the WCTS main flowing without blockage?	Is there a blockage in the lower lateral?	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Actions
76	2/12/2019	12:54	3563 TROUTDALE COURT, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/12/2019	1:14	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
77	2/12/2019	16:04	1864 MASON MILL ROAD	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	2/12/2019	16:40	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
78	2/12/2019	4:05	4291 EAST KINGS POINT CIRCLE, DUNWOODY	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/12/2019	4:20	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
79	2/13/2019	4:00	3429 CANADIAN WAY, TUCKER	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/13/2019	5:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
80	2/13/2019	7:45	1030 SOUTH MILLARD WAY, STONE MOUNTAIN	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/13/2019	8:45	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
81	2/14/2019	9:00	3803 BROOKCREST CIRCLE, DECATUR	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	2/14/2019	9:15	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
82	2/14/2019	11:30	805 DENSLEY DRIVE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/14/2019	12:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
83	2/14/2019	5:00	1583 KNOB HILL DRIVE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/14/2019	5:20	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
84	2/16/2019	11:40	2048 WESLEY CHAPEL ROAD, DECATUR	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	2/16/2019	11:50	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
85	2/18/2019	12:00	6560 ALFORD WAY, LITHONIA	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	2/18/2019	12:30	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
86	2/18/2019	4:25	3933 JERICO ROAD, TUCKER	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/18/2019	5:55	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
87	2/19/2019	10:55	2543 STAFFORD PLACE, DORAVILLE	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/19/2019	11:20	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
88	2/20/2019	7:00	4260 BINGHAM COURT, STONE MOUNTAIN	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/20/2019	10:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
89	2/20/2019	10:49	2985 LAGUNA DRIVE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/20/2019	11:29	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
90	2/20/2019	4:30	4931 VERMACK ROAD, DUNWOODY	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/20/2019	9:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW



**DeKalb County Department of Watershed Management**

**Lateral Related Issues\***

Lateral Issue No.	Date/Time		Location			Cause/Source	Flow Restoration		
	Date Reported to DWM	Time Reported to DWM	Address	Is the WCTS main flowing without blockage?	Is there a blockage in the lower lateral?	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Actions
91	2/21/2019	12:30	2612 CLIFTON RUN PLACE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/21/2019	12:45	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
92	2/21/2019	1:30	1978 LAUREL LANE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/21/2019	2:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
93	2/23/2019	8:25	1907 CLAIRMONT TERRACE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/23/2019	9:25	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
94	2/24/2019	10:10	133 MELROSE AVENUE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/24/2019	12:10	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
95	2/24/2019	12:00	3060 MOUNT OLIVE DRIVE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/24/2019	1:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
96	2/25/2019	8:30	4743 FELLWOOD DRIVE, STONE MOUNTAIN	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/25/2019	9:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
97	2/25/2019	9:30	4326 WARD BLUFF COURT, ELLENWOOD	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	2/25/2019	9:45	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
98	2/25/2019	2:30	3402 RIVERVIEW CHASE WAY, ELLENWOOD	No	Yes	THERE WAS AN ISSUE IN BOTH THE WCTS AND THE LATERAL	2/25/2019	2:40	BLOCKAGES REMOVED FROM WCTS AND LATERAL TO RESTORE FLOW
99	2/25/2019	3:20	2077 MALABAR DRIVE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/25/2019	4:50	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
100	2/26/2019	3:40	3621 GREENTREE FARMS DRIVE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/26/2019	3:55	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
101	2/27/2019	10:31	4264 WINTERS CHAPEL ROAD	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	2/27/2019	11:00	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
102	2/27/2019	10:50	2370 CRESTA DRIVE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/27/2019	11:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
103	2/27/2019	12:00	848 NEEDLE ROCK DRIVE, STONE MOUNTAIN	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	2/27/2019	12:15	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
104	2/27/2019	5:40	3949 HARTS MILL LANE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	2/27/2019	6:05	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
105	2/27/2019	7:15	1226 CLAIRMONT ROAD, DECATUR	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	2/27/2019	7:30	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED

## DeKalb County Department of Watershed Management

### Lateral Related Issues\*

Lateral Issue No.	Date/Time		Location			Cause/Source	Flow Restoration		
	Date Reported to DWM	Time Reported to DWM	Address	Is the WCTS main flowing without blockage?	Is there a blockage in the lower lateral?	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Actions
106	3/2/2019	12:20	4077 ROCKEY VALLEY DRIVE, CONLEY	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/2/2019	12:50	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
107	3/4/2019	12:10	1888 ROBINHILL COURT, TUCKER	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/4/2019	12:25	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
108	3/5/2019	9:00	4121 CEDAR RIDGE TRAIL, STONE MOUNTAIN	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/5/2019	10:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
109	3/5/2019	10:05	2288 4TH STREET, TUCKER	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/5/2019	11:05	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
110	3/5/2019	10:45	1033 TEXEL LANE, CLARKSTON	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/5/2019	11:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
111	3/5/2019	12:25	3866 RAINS COURT, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/5/2019	12:55	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
112	3/5/2019	6:35	2370 CRESTA DRIVE, DECATUR	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/5/2019	6:50	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
113	3/6/2019	5:00	2914 LEISURE WOODS LANE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/6/2019	5:45	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
114	3/6/2019	4:35	2377 MIDVALE CIRCLE, TUCKER	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/6/2019	5:35	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
115	3/6/2019	6:35	2017 CASTLEWAY LANE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/6/2019	7:35	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
116	3/7/2019	7:00	3589 NORTH DECATUR ROAD, SCOTTDALE	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/7/2019	10:15	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
117	3/7/2019	11:30	1347 TALCOTT PLACE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/7/2019	1:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
118	3/8/2019	9:00	1663 DRESDEN DRIVE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/8/2019	11:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
119	3/8/2019	12:30	1451 COLONY HILL COURT, STONE MOUNTAIN	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/8/2019	5:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
120	3/8/2019	11:45	4911 WIND COVE COURT, STONE MOUNTAIN	No	Yes	THERE WAS AN ISSUE IN BOTH THE WCTS AND THE LATERAL	3/8/2019	12:00	BLOCKAGES REMOVED FROM WCTS AND LATERAL TO RESTORE FLOW

**DeKalb County Department of Watershed Management**

**Lateral Related Issues\***

Lateral Issue No.	Date/Time		Location		Cause/Source		Flow Restoration		
	Date Reported to DWM	Time Reported to DWM	Address	Is the WCTS main flowing without blockage?	Is there a blockage in the lower lateral?	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Actions
121	3/8/2019	3:00	758 DENSLEY DRIVE, DECATUR	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/8/2019	3:30	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
122	3/9/2019	9:50	2211 ACELIA COURT, DECATUR	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/9/2019	10:05	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
123	3/9/2019	2:30	758 DENSLEY DRIVE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/9/2019	3:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
124	3/10/2019	6:00	2592 BOULDER HILL COURT, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/10/2019	6:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
125	3/10/2019	16:19	1832 CEDAR GROVE ROAD	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/10/2019	17:45	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
126	3/11/2019	9:50	1298 DRAYTON WOODS DRIVE, TUCKER	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/11/2019	10:05	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
127	3/11/2019	11:20	2140 TWIN FALLS ROAD, DECATUR	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/11/2019	11:35	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
128	3/11/2019	2:20	2087 WRIGHTS MILL CIRCLE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/11/2019	3:20	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
129	3/11/2019	2:30	5155 CENTRAL DRIVE, STONE MOUNTAIN	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/11/2019	3:00	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
130	3/11/2019	7:25	2622 BALL PARK DRIVE, TUCKER	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/11/2019	8:25	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
131	3/12/2019	10:30	1688 KNOB HILL COURT, ATLANTA	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/12/2019	10:50	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
132	3/12/2019	1:15	4577 VILLAGE SPRINGS PLACE, DUNWOODY	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/12/2019	1:25	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
133	3/19/2019	9:53	1236 SPRING VALLEY LANE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/19/2019	9:53	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
134	3/13/2019	2:00	2263 CLAIRMONT ROAD, ATLANTA	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/13/2019	5:00	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
135	3/13/2019	6:50	3101 FALA PLACE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/13/2019	7:50	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW

## DeKalb County Department of Watershed Management

### Lateral Related Issues\*

Lateral Issue No.	Date/Time		Location		Cause/Source		Flow Restoration		
	Date Reported to DWM	Time Reported to DWM	Address	Is the WCTS main flowing without blockage?	Is there a blockage in the lower lateral?	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Actions
136	3/13/2019	11:30	3626 PREAKNESS DRIVE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/14/2019	12:15	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
137	3/14/2019	11:20	465 EMORY DRIVE, ATLANTA	No	Yes	THERE WAS AN ISSUE IN BOTH THE WCTS AND THE LATERAL	3/14/2019	11:40	BLOCKAGES REMOVED FROM WCTS AND LATERAL TO RESTORE FLOW
138	3/14/2019	12:50	2263 CLAIRMONT ROAD, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/14/2019	1:50	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
139	3/15/2019	1:00	5981 ARBOR LINKS ROAD, LITHONIA	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/15/2019	1:25	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
140	3/15/2019	7:00	2264 OAKAWANA ROAD, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/15/2019	8:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
141	3/15/2019	5:30	3500 HILDON CIRCLE, CHAMBLEE	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/15/2019	6:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
142	3/16/2019	2:30	1875 GRAMERCY COURT, DUNWOODY	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/16/2019	3:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
143	3/18/2019	8:20	404 COVENTRY ROAD, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/18/2019	9:20	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
144	3/18/2019	10:00	1447 SAGAMORE DRIVE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/18/2019	10:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
145	3/18/2019	9:30	209 COVENTRY ROAD, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/18/2019	10:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
146	3/18/2019	10:30	826 PINETREE DRIVE, DECATUR	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/18/2019	11:00	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
147	3/18/2019	10:55	4196 BUFORD HIGHWAY	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/18/2019	11:55	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
148	3/18/2019	12:30	1901 PONCE DE LEON AVENUE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/18/2019	12:45	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
149	3/18/2019	4:10	1601 IDLEWOOD ROAD, TUCKER	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/18/2019	5:10	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
150	3/18/2019	3:00	1678 LIBERTY VALLEY, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/18/2019	4:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW

## DeKalb County Department of Watershed Management

### Lateral Related Issues\*

Lateral Issue No.	Date/Time		Location		Cause/Source		Flow Restoration		
	Date Reported to DWM	Time Reported to DWM	Address	Is the WCTS main flowing without blockage?	Is there a blockage in the lower lateral?	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Actions
151	3/19/2019	12:38	1037 VAUGHN STREET	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/19/2019	13:15	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
152	3/19/2019	1:00	4138 EAST PONCE DE LEON AVENUE, CLARKSTON	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/19/2019	1:15	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
153	3/21/2019	3:30	898 CLUBHOUSE CIRCLE, DECATUR	No	Yes	THERE WAS AN ISSUE IN BOTH THE WCTS AND THE LATERAL	3/21/2019	4:30	BLOCKAGES REMOVED FROM WCTS AND LATERAL TO RESTORE FLOW
154	3/22/2019	12:00	4720 KLONDIKE CIRCLE, LITHONIA	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/22/2019	12:15	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
155	3/21/2019	10:00	2036 LAKESPRINGS WAY, DUNWOODY	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/21/2019	10:45	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
156	3/22/2019	12:00	4369 SASANQUA COURT, TUCKER	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/22/2019	12:30	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
157	3/22/2019	8:40	2161 CHESTNUT HILL CIRCLE, DECATUR	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/22/2019	9:00	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
158	3/23/2019	9:35	1992 ROYAL COURT, CHAMBLEE	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/23/2019	10:05	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
159	3/23/2019	9:30	2161 CHESTNUT HILL CIRCLE, DECATUR	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/23/2019	9:40	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
160	3/24/2019	12:30	4593 NORTH PEACHTREE ROAD, DUNWOODY	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/24/2019	1:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
161	3/25/2019	7:00	3428 WOODS DRIVE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/25/2019	11:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
162	3/25/2019	11:00	4700 GLENWOOD ROAD, DECATUR	No	Yes	THERE WAS AN ISSUE IN BOTH THE WCTS AND THE LATERAL	3/25/2019	11:15	BLOCKAGES REMOVED FROM WCTS AND LATERAL TO RESTORE FLOW
163	3/25/2019	8:10	6375 DAISY LANE, LITHONIA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/25/2019	9:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
164	3/25/2019	7:00	3947 BUTTON GATE COURT, LITHONIA	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/25/2019	7:25	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
165	3/25/2019	1:00	3245 HARBOR WOODS ROAD, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/25/2019	1:40	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW



## DeKalb County Department of Watershed Management

### Lateral Related Issues\*

Lateral Issue No.	Date/Time		Location		Cause/Source		Flow Restoration		
	Date Reported to DWM	Time Reported to DWM	Address	Is the WCTS main flowing without blockage?	Is there a blockage in the lower lateral?	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Actions
166	3/25/2019	2:15	1618 PINE GLEN CIRCLE, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/25/2019	2:35	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
167	3/25/2019	3:35	2095 COLUMBIA DRIVE, DECATUR	No	Yes	THERE WAS AN ISSUE IN BOTH THE WCTS AND THE LATERAL	3/25/2019	4:35	BLOCKAGES REMOVED FROM WCTS AND LATERAL TO RESTORE FLOW
168	3/26/2019	11:40	4063 GLENWOOD ROAD, DECATUR	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/26/2019	11:55	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
169	3/28/2019	12:45	4433 EAST KINGS POINT CIRCLE, DUNWOODY	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/28/2019	1:15	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
170	3/28/2019	4:50	2106 NORTH PONCE DE LEON AVENUE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/28/2019	5:50	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
171	3/29/2019	5:20	2074 ZELDA DRIVE, ATLANTA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/29/2019	6:00	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
172	3/29/2019	20:08	1111 CLAIREMONT AVENUE	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/29/2019	20:30	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW
173	3/29/2019	8:15	1211 CLAIRMONT ROAD, DECATUR	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/29/2019	8:30	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
174	3/30/2019	12:40	510 NELSON FERRY ROAD, DECATUR	Yes	Yes	OVERFLOW CAUSED BY LOWER LATERAL MAINTENANCE RELATED BLOCKAGE	3/30/2019	1:50	FLOW RESTORED TO LATERAL AND OVERFLOW AREA CLEANED
175	3/30/2019	8:13	3863 SNAPFINGER ROAD, LITHONIA	Yes	Yes	MAINTENANCE RELATED BLOCKAGE IN PRIVATE LATERAL	3/30/2019	8:28	BLOCKAGE REMOVED FROM PRIVATE LATERAL TO RESTORE FLOW

\*The County was asked at our meeting of April 14, 2016 to begin tracking SSO's that appear to be caused by blockages or other issues located in that section of a private service lateral that is in the County's right-of-way. This report reflects the County's best efforts to track this information.